



# Goodwill Excel Center PCS - Lead in Water Test Results



## FY21 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Goodwill Excel Center PCS	WS-015-001	Break Room	1	In first floor staff lounge			WF-022021-015001-04	6/24/2021	FT-FY21-022021-015001-A	<1	FT-FY21-022021-015001-B	<1
Goodwill Excel Center PCS	WS-015-002	Classroom Faucet	1	In classroom 1 in daycare			WF-022021-015002-04	6/24/2021	FT-FY21-022021-015002-A	<1	FT-FY21-022021-015002-B	<1
Goodwill Excel Center PCS	WS-015-003	Classroom Faucet	1	In classroom 2 in daycare			WF-022021-015003-04	6/24/2021	FT-FY21-022021-015003-A	2.9	FT-FY21-022021-015003-B	<1
Goodwill Excel Center PCS	WS-015-004	Classroom Faucet	1	In classroom 3 in daycare			WF-022021-015004-04	6/24/2021	FT-FY21-022021-015004-A	1.3	FT-FY21-022021-015004-B	<1
Goodwill Excel Center PCS	WS-015-005	Cooler	Basement	In basement lobby	High	Left	WF-022021-015005-04	N/A	FT-FY21-022021-015005-A	Non-Op	FT-FY21-022021-015005-B	Non-Op
Goodwill Excel Center PCS	WS-015-006	Cooler	Basement	In basement lobby	Low	Right	WF-022021-015006-04	N/A	FT-FY21-022021-015006-A	Non-Op	FT-FY21-022021-015006-B	Non-Op
Goodwill Excel Center PCS	WS-015-007	Bottle Filler	Basement	In basement lobby	High	Right	WF-022021-015007-04	N/A	FT-FY21-022021-015007-A	Non-Op	FT-FY21-022021-015007-B	Non-Op
Goodwill Excel Center PCS	WS-015-008	Break Room	Basement	In basement lobby			WF-022021-015008-04	6/24/2021	FT-FY21-022021-015008-A	1.8	FT-FY21-022021-015008-B	<1
Goodwill Excel Center PCS	WS-015-009	Break Room	Basement	In staff lounge			WF-022021-015009-04	6/24/2021	FT-FY21-022021-015009-A	<1	FT-FY21-022021-015009-B	<1